

LEGEND

M.1

Water Meter Assembly

---

Property Boundary

---

Road Carriage Way

W


Water Main

RM

Rider Main

■

Water House Connection



DETAIL 1 - Water Main Up To 150ND  
(Refer to Note 5)

Notes:

- A building must be no more than 80 metres from a water main to receive a water service. Buildings more than 80 metres from a water main will require a sub-main extension.
- Each freehold property is allowed one (1) property service connection only. If the property owner subdivides the property, SWA will not provide additional services connections.
- Water meters shall be installed outside the property boundary only, as close as practically possible to the boundary line. The connection of the property from the meter assembly is the responsibility of the property owner.
- Water meters shall be installed "below ground" (as per Drawing No. W - 017) unless otherwise directed by SWA.
- Water service connections shall be connected directly to water mains up to 150ND. For water mains greater than 150 ND, the water service connection shall be connected to the adjacent rider main (Refer to Drawing No. W - 002.)

	BY	DATE	REV	DESCRIPTIONS	DATE	APPROVED
DESIGNED :	P.R	...			...	--
DRAWN :	T.A	...			...	--
DSGN CHECKED :	P.R	...			...	--
DWG CHECKED :	P.R	...			...	--
APPROVED :	T.M.T.T	...			...	--

DRAWING TITLE :	PROPERTY SERVICE CONNECTIONS GENERAL
-----------------	---

PROJECT TITLE :	STANDARD DRAWING
-----------------	------------------

SAMOA WATER AUTHORITY

Level 2 TATTE Building  
Apia, Sogi  
Ph: +685 20409  
Fax: +685 21298

SIZE	CONTRACT NUMBER :	REVISION
A3		2
SCALE :	DRAWING NUMBER :	
N.T.S	W - 016	